

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 1450-1342:114

Page 1 of 1

CATEGORY: Expansion Joints

LISTEE: Watson Bowman Acme, 95 Pineview Drive, Amherst NY 14228
Contact: John Sobol (716) 691-7566 Fax (716) 691-9239

DESIGN: Horizontal expansion/seismic joint systems with 0.073" thick stainless steel and 0.079" thick aluminum plate over WABO fire blanket with stainless steel foil. 13-2/3' long, 12", 16-1/2" and 18" wide. in 13-2/3' x 17-1/2' deck (floor/ceiling) of precast concrete restrained assembly with total load of 100 lbs/ft². Refer to listee's data sheet and WHI Listings Book for detailed product description, assembly components and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Warnock Hersey Inc. label.

APPROVAL: Listed as a horizontal expansion joint system for use in precast concrete deck (floor/ceiling) where 4-hour fire-rated protection is needed.

07-25-94



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**